

# Sanbornton Fire Department

565 Sanborn Rd./P.O. Box 112  
Sanbornton, NH 03269

Fire Chief  
Paul D. Dexter Jr.

Phone (603) 286-4819  
Fax (603) 286-4023

December 3, 2015

Requirements for Installation and Operation of Heating Appliances (State Fire Code Part Saf-C6011)

## GOVERNING CODES:

Oil Burning Equipment (including replacement of supply/storage tanks)

- NFPA 31 and referenced codes therein for Oil Burning Equipment
- State Fire Code Part Saf-C 6012
- NFPA 211
- State Fire Code Part Saf-C 6013

LP or Natural Gas equipment or appliances (including replacement of supply/storage tanks)

- NFPA 54
- NFPA 58
- NFPA 1
- NFPA 211
- State Fire Code Part Saf-C 6009

Stationary Automatic Generators

- NFPA 37
- NFPA 54
- NFPA 58
- NFPA 555
- NFPA 70

Solid Fuel Burning Appliances (woodstoves, pellet stoves and outside wood furnaces)

- NFPA 211

## APPLICATION & PERMITS:

- Town of Sanbornton Fire Department's "Permit to Install and Operate Heating Appliances" found at the Town of Sanbornton's web page ([Sanborntonnh.org](http://Sanborntonnh.org)) or at the town offices and the central fire station.

## INSPECTIONS REQUIRED:

- Fire Department – final equipment operation stage
- 24 hour notice is required unless other arrangements have been made prior to installation.
- The installer WILL be present during the final inspection
- If supply lines are to be buried inspection prior to covering the supply lines must be conducted.

Page 1 of 2



**[WWW.SANBORNTONNH.ORG](http://WWW.SANBORNTONNH.ORG)**

DOCUMENTS REQUIRED:

- Installation manual – provided to owner.
- A service tag will be affixed in the area of the oil burning equipment with the name of the installer, contact information, the date of install and that the equipment meets operation and combustion performance criteria.
- Copy of the “Permit to Install or Operate” shall be conspicuously posted near the appliance, and be available at the time of the final inspection.

Yours if public safety,

*Paul D. Dexter Jr.*

Paul D. Dexter Jr.  
Fire Chief / EMD